## **TEST CERTIFICATE**

Extract of report no.: 300-ELAB-2216

Manufacturer: NBE Production A/S

Kjeldgaardsvej 2, 9300 Sæby

CVR nr. 34890323

**Product:** Biofuel boiler

P nr. 1018144723

DANISH TECHNOLOGICAL INSTITUTE

Model: RTB 80

**Procedure:** Testing according to EN 303-5:2012

Requirements: Commission regulation (EU) No. 2015/1189, Annex II, Article 1

Stoking princ.: Automatic Fuel: Biomass

Testing has been carried out with wood pellets (C1) with the following results:

## **TEST RESULTS**

Measurement	Unit	Result	Limits
Nominal heat output	kW	78	
CO at 10% O <sub>2</sub>	mg/m <sub>n</sub> <sup>3</sup>	110	
OGC at 10% O <sub>2</sub>	mg/m <sub>n</sub> <sup>3</sup>	< 6	
Dust at 10% O <sub>2</sub>	mg/m <sub>n</sub> <sup>3</sup>	20	
NO <sub>x</sub> at 10% O <sub>2</sub>	mg/m <sub>n</sub> <sup>3</sup>	152	
Efficiency	%	93,6	
Minimum heat output	kW	23	
CO at 10% O <sub>2</sub>	mg/m <sub>n</sub> <sup>3</sup>	82	
OGC at 10% O <sub>2</sub>	mg/m <sub>n</sub> <sup>3</sup>	< 6	
Dust at 10% O <sub>2</sub>	mg/m <sub>n</sub> <sup>3</sup>	30	
NO <sub>x</sub> at 10% O₂	mg/m <sub>n</sub> <sup>3</sup>	132	
Efficiency	%	93,9	
Seasonal emissions			
CO at 10% O <sub>2</sub>	mg/m <sub>n</sub> <sup>3</sup>	86	500
OGC at 10% O <sub>2</sub>	mg/m <sub>n</sub> <sup>3</sup>	< 6	20
Dust at 10% O <sub>2</sub>	mg/m <sub>n</sub> <sup>3</sup>	28	40
NO <sub>x</sub> at 10% O₂	mg/m <sub>n</sub> <sup>3</sup>	135	200
Seasonal space heating energy efficiency			
ης	%	83,0	77
ηson	%	86,9	
F1	%	3,0	
F2	%	0,8	

Please note that the stated values are an extract from the test report. For further information please refer to the test report.

Aarhus, 17. January 2018

Anders Pødenphant

B. Sc.

This certificate has been conducted and calculated on the basis of an accreditated test report performed by the test institute under the accreditation of DANAK member of EA and ILAC.

ED Certificate 300-ELAB-2216